

Number	K25301/02	Replaces	K25301/01
Issued	2008-02-01	Dated	2004-09-15


Product Certificate
Metal fittings

Based on pre-certification tests as well as periodic inspections by Kiwa, the products referred to in this certificate and marked with the Kiwa-mark as indicated under 'Marking', manufactured by

APE Raccorderie S.r.l.

may, on delivery, be relied upon to comply with

Kiwa evaluation guideline BRL-K536, Part E
"Plastic piping systems of Aluminium/PE-X, for the
transport of cold and hot drinking water".



ing. B. Meekma
Director Certification and Inspection, Kiwa N.V.

This certificate is issued in accordance with the Kiwa-Regulations for Product Certification.

This certificate consists of 3 pages.
Publication of the certificate is allowed.

Supplier

APE Raccorderie S.r.l.
Via Gozzano, 8
Frazione Ponte Zanano
I-25068 SAREZZO (BS)
Italy

Phone: +39 30. 8920912
Fax: +39 30. 8926624
info@ape-raccorderie.com

Kiwa N.V.
Certification and Inspection
Sir W. Churchill-laan 273
Postbus 70
2280 AB Rijswijk
The Netherlands

Tel. +31 70 41 44 400
Fax +31 70 41 44 420
Internet www.kiwa.nl

Certificate

Metal fittings

PRODUCT SPECIFICATION

The following products belong to this certificate.

Press- fittings APE:

Ø16

Ø20

Ø26

The belonging case NEUTRO:

3APSTX 16 Ø16

3APSTX 20 Ø20

3APSTX 26 Ø26

Press- fitting APE x outer thread:

3AP101 1216 ½"- Ø16

3AP101 1220 ½"- Ø20

3AP101 3426 ¾"- Ø26

Metal fittings

APPLICATION AND USE

Metal fittings for plastic piping systems used for transport of cold or hot drinking water with a maximum temperature of 70 C° and maximum working pressure of 1000 kPa.

MARKING

The products are marked with the Kiwa- mark.

Place of the mark:

- on the belonging tube.

Compulsory specifications:

- company name or trade name;
- outside diameter of belonging tube in mm;
- name of the systems trade name;
- date of production.

Method of marking:

- non-erasable;
 - visible after assembly.
-

RECOMMENDATIONS FOR CUSTOMERS:

1. Check at the time of delivery whether:
 - 1.1 the producer has delivery in accordance with the agreement;
 - 1.2 the mark and the marking method are correct;
 - 1.3 the products show no visible defects as a result of transport etc.
 2. If you should reject a product on the basis of the above, please contact:
 - 2.1 APE Raccorderie S.r.l.
and, if necessary,
 - 2.2 Kiwa N.V.
 3. Consult the producer's processing guidelines for the proper storage and transport methods.
 4. Check whether this certificate is still valid by consulting www.kiwa.nl
-